

Attestation of Conformity

No.: OViS202603137EEIC

Page 1 of 1

Holder of Certificate: TAIZHOU FLOWFORCE AI TECHNOLOGY CO.,LTD
Room 1402-04,Building 2,Chuangye Mansion,No.1333 Wanchang
Address: Middle Road,Chengdong Street,317500 Wenling,Taizhou,
Zhejiang,PEOPLE'S REPUBLIC OF CHINA
Manufacturer: TAIZHOU FLOWFORCE AI TECHNOLOGY CO.,LTD
Room 1402-04,Building 2,Chuangye Mansion,No.1333 Wanchang
Address: Middle Road,Chengdong Street,317500 Wenling,Taizhou,
Zhejiang,PEOPLE'S REPUBLIC OF CHINA
Factory: TAIZHOU FLOWFORCE AI TECHNOLOGY CO.,LTD
Room 1402-04,Building 2,Chuangye Mansion,No.1333 Wanchang
Address: Middle Road,Chengdong Street,317500 Wenling,Taizhou,
Zhejiang,PEOPLE'S REPUBLIC OF CHINA
Product: Circulation pump Energy Saving Circulation Pumps
Model(s): WHM25-60 180
Test Report No.: OViS202603137EEI
Parameters: 230V, 50/60Hz,50 W Max., Class I, IP44, TF110, 3,4m³/h
Declared EEI: Less than 0.23
Implementation Measure EC Regulation
No 641/2009: 2009-07-22 amended by
(EU) 622/2012:2012-07-11, (EU) 2016/2282: 2016-11-30,
(EU) 2019/1781:2019-10-01
Stage 2 (2015-08-01)
Tested according to: EN 16297-1:2012, EN 16297-2:2012, EN 16297-3:2012

Remark(s): This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the sample submitted to OViS Testing Technology (Zhejiang) Co., Ltd for testing and evaluation and to its technical documentation.

Issuance date:

Apr. 22, 2026

Expiration Date:

Apr. 21, 2030



OViS Testing Technology (Zhejiang) Co., Ltd.

Building 31, Feiyue Park, Xiachen Street, Jiaojang District, Taizhou City,
Zhejiang Province, China

www.ovis-lab.com info@ovis-lab.com Tel:400-8008-959